

(Add) **R326.6 Barrier requirements.** The provisions of this section *shall* control the design of barriers for residential *swimming pools*, spas and hot tubs. These design controls are intended to provide protection against potential drownings and near-drownings by restricting access to *swimming pools*, spas and hot tubs.

(Add) **R326.6.1 Outdoor swimming pool.** An outdoor swimming pool, including an in-ground, above-ground or on-ground pool, hot tub or spa, *shall* be surrounded by a barrier which *shall* comply with the following:

1. The top of the barrier *shall* be at least 48 inches (1219 mm) above grade measured on the side of the barrier which faces away from the swimming pool. The maximum vertical clearance between grade and the bottom of the barrier *shall* be 2 inches (51 mm) measured on the side of the barrier which faces away from the swimming pool. Where the top of the pool structure is above grade, such as an above-ground pool, the barrier may be at ground level, such as the pool structure, or mounted on top of the pool structure. Where the barrier is mounted on top of the pool structure, the maximum vertical clearance between the top of the pool structure and the bottom of the barrier *shall* be 4 inches (102 mm).
2. Openings in the barrier *shall* not allow the passage of a 4-inch-diameter (102 mm) sphere.
3. Solid barriers which do not have openings, such as a *masonry* or stone wall, *shall* not contain indentations or protrusions, except for normal construction tolerances and tooled *masonry* joints.
4. Where the barrier is composed of horizontal and vertical members, and the distance between the tops of the horizontal members is less than 45 inches (1143 mm), the horizontal members *shall* be located on the swimming pool side of the fence. Spacing between vertical members *shall* not exceed 1¾-inches (44 mm) in width. Where there are decorative cutouts within vertical members, spacing within the cutouts *shall* not exceed 1¾-inches (44 mm) in width.
5. Where the barrier is composed of horizontal and vertical members, and the distance between the tops of the horizontal members is 45 inches (1143 mm) or more, spacing between vertical members *shall* not exceed 4 inches (102 mm). Where there are decorative cutouts within vertical members, spacing within the cutouts *shall* not exceed 1¾-inches (44 mm) in width.
6. Maximum mesh size for chain link fences *shall* be a 2¼-inch (57 mm) square, unless the fence has slats fastened at the top or the bottom which reduce the openings to not more than 1¾-inches (44 mm).
7. Where the barrier is composed of diagonal members, such as a lattice fence, the maximum opening formed by the diagonal members *shall* not be more than 1¾ inches (44 mm).
8. Access gates *shall* comply with the requirements of Items 1 through 7, and *shall* be equipped to accommodate a locking device. Pedestrian access gates *shall* open outward away from the pool, and *shall* be *self-closing* and have a self-latching device. Gates, other than pedestrian access gates, *shall* have a self-latching device. Where the release mechanism of the self-latching device is located less than 54 inches (1372 mm) from the bottom of the gate, the release mechanism and openings *shall* comply with the following:
 - 8.1 The release mechanism *shall* be located on the pool side of the gate at least 3 inches (76 mm) below the top of the gate; and
 - 8.2 The gate and barrier *shall* have no opening larger than 1/2 inch (12.7 mm) within 18 inches (457 mm) of the release mechanism.
9. Where a wall of a *dwelling* serves as part of the barrier, one of the following conditions *shall* be met:
 - 9.1 The pool *shall* be equipped with a powered safety cover in compliance with ASTM F1346;
 - 9.2 Doors with direct access to the pool through that wall *shall* be equipped with an alarm that produces an audible warning when the door and/or its screen, if present, are opened. The alarm *shall* be *listed* and *labeled* in accordance with UL 2017. The deactivation switch(es) *shall* be located at least 54 inches (1372 mm) above the threshold of the door; or

of protection afforded is not less than the protection afforded by Item 9.1 or 9.2 described herein.

10. Where an above-ground or on-ground pool structure is used as a barrier or where the barrier is mounted on top of the pool structure, and the means of access is a ladder or steps, the ladder or steps *shall* be surrounded by a barrier that meets the requirements of Section AG105.2, Items 1 to 9, inclusive.

(Add) **R326.6.2 Indoor swimming pool.** Walls surrounding an indoor swimming pool *shall* comply with Item 9 of Section R326.6.1.

(Add) **R326.6.3 Barrier perimeter clearance.** The required barrier height *shall* exist around the entire perimeter of the barrier and for a distance of 3 feet (914 mm) measured horizontally from the outside of the required barrier, free of structures, equipment or similar objects.

(Add) **R326.6.4 Barrier exceptions.** Spas or hot tubs with a safety cover which comply with ASTM F1346 *shall* be exempt from the provisions of this chapter.

(Add) **R326.6.5 Temporary enclosure.** A temporary enclosure *shall* be installed prior to the electrical bonding inspection of any in-ground swimming pool unless the permanent barrier specified in Section R326.6.1 is in place prior to the commencement of the installation. The temporary enclosure *shall* be a minimum of 4 feet (1219) in height, *shall* have no openings that will allow passage of a 4-inch (102 mm) sphere and *shall* be equipped with a positive latching device on any openings.

(Add) **R326.6.6 Pool alarm.** Pursuant to section 29-265a of the Connecticut General Statutes, no building *permit shall* be issued for the construction or substantial *alteration* of a swimming pool at a residence occupied by, or being built for, one or more families unless a pool alarm is installed with the swimming pool. As used in this section, "pool alarm" means a device that emits a sound of at least 50 decibels when a person or an object weighing 15 pounds (6.8 kg) or more enters the water in a swimming pool.

Exception: Hot tubs and portable spas *shall* be exempt from this requirement.

I HAVE READ AND UNDERSTANT THE ABOVE CODE REQUIREMENTS AND AGREE TO INSTALL THE POOL FENCE AND REQUIRED POOL ALARM ON MY PROPERTY IN COMPLIANCE WITH THE ABOVE.

SIGNATURE OF HOMEOWNER _____

ADDRESS OF HOMEOWNER _____

ADDRESS OF PROPERTY WHERE POOL IS BEING INSTALLED _____

DATE _____

TOWN OF DARIEN
OFFICE OF BUILDING OFFICIAL
2 RENSHAW ROAD - TOWN HALL
DARIEN, CT 06820-5397
TELEPHONE (203) 656-7347
FAX (203) 656-7385



PETER E. SOLHEIM
HEAD BUILDING OFFICIAL

MICHAEL E. VITTI
ASSISTANT BUILDING OFFICIAL

Gary Willson
Electrical/Building Official

Swimming Pool Water Alarm

Substitute House Bill No. 5070

Public Act No. 99-140 (see attached)

All Swimming pools are required to have a device which emits a sound of at least fifty decibels when a person or an object weighing fifteen pounds or more enters the water.

Building Permit # _____

Building Address _____

Property Owner _____

Pool Contractor _____


Witness _____

Owner's signature _____

Print Name _____

Subscribed and sworn to before me this _____ day of _____, 20____

Notary _____



Substitute House Bill No. 5070

Public Act No. 99-140

An Act Concerning Alarms for New Swimming Pools.

Be it enacted by the Senate and House of Representatives in General Assembly convened:

(NEW) (a) As used in this section, "pool alarm" means a device which emits a sound of at least fifty decibels when a person or an object weighing fifteen pounds or more enters the water in a swimming pool.

(b) No building permit shall be issued for the construction or substantial alteration of a swimming pool at a residence occupied by, or being built for, one or more families unless a pool alarm is installed with the swimming pool.

Approved June 8, 1999

TOP