

## Doneit, Fred

---

**From:** Oustafine, Darren  
**Sent:** Thursday, May 28, 2020 5:31 PM  
**To:** Ginsberg, Jeremy; Doneit, Fred  
**Subject:** 5 Homewood

Dear Messer's Ginsberg & Doneit:

We offer the following review comments relative to the above captioned land use application, per your request.

- Homewood is a private road. street opening permit not necessary.
- No town sewer available.
- Application includes additions to existing dwelling, stone walls, and driveway expansion which all increase impervious area on subject lot.
- No stormwater management report found nor reviewed.
- Impervious area to be added is nominal increase to site, and is contiguous with existing hardscape and building.

Thanks.

Darren

Darren Oustafine, P.E., Assistant Director of Public Works  
Town of Darien DPW  
2 Renshaw Road – Town Hall  
Darien, CT 06820  
Office 203-656-7365  
Email [doustafine@darienct.gov](mailto:doustafine@darienct.gov)