

Reminders for Pool Operators

- 1) Check Chlorine and pH levels BEFORE opening the pool in the morning and at least 3 additional times during the day. Enter all readings in the log book & keep the log book accessible for inspection.**
- 2) After adding any chemicals to the pool, make sure to check both ph & chlorine levels to see how these additions affect pool water chemistry. Make a note of any added chemicals in the Log Book.**
- 3) ALWAYS maintain chlorine levels between 1.0 and 3.0 mg/l.**
- 4) ALWAYS maintain pH between 7.2 and 7.8**
- 5) Clean skimmer baskets daily and make sure skimmers are balanced, especially after vacuuming.**

Any questions? Please call the Darien Health Department at 656-7320